

No.-125/2026

“ഭരണഭാഷ-മാതൃഭാഷ”



STATION OFFICER

FIRE & RESCUE STATION, PAMPADY

DATED: 13.04.2026

PHONE: 0481-2506600

E-mail ID: ppd.frs@kerala.gov.in

NO OBJECTION CERTIFICATE
(RENEWAL)

The board headed by the Station Officer Fire and Rescue Station Pampady had inspected the (G+2) Educational Building having a height of 09.90m and with total plinth area 2748.35m² in Survey No.81/1 in Pampady Village, Kottayam Taluk, in Kottayam District Under Pampady Gramapanchayath Owned by The Manager, Vimalambika Public School, Pampady(P.O), Kottayam and recommended to renewal of No Objection Certificate No.G-4676/2016, Dated 21.06.2016 of The District Fire Officer, Fire and Rescue Services, Kottayam for the occupation of the said Building as per report NO.C:125/2026, Dated: 13/04/2026 of the Station Officer Fire and Rescue station Pampady for **One year**

2. In the circumstances this No Objection Certificate is issued under my seal and authority for the continued occupation of the above building. No further construction will be allowed in the vacant spaces provided in the approved plan.

3. The certificate is issued on the condition that the fire fighting system installed will be kept always functional and the owner of the building should take special care to maintain the systems installed in proper working condition. **This certificate is valid for one year from the date of issue. After one year the certificate must be renewed. Non renewal of the certificate within the time limit will result in loss of eligibility for insurance coverage and appropriate legal action by the local self government/ Revenue Department.** All officers of and above the rank of Station Officers of the fire and Rescue Services Department will have the right to inspect the building on any day/time after serving 7 days notice to ensure that the installed systems are in good working condition.

4. This Certificate is valid from 13.04.2026 to 12.04.2027 Only.



P. Anand
STATION OFFICER
Fire & Rescue Station
Pampady - 686 502