



TC-10495

QUALITY CONTROL DISTRICT LAB
KERALA WATER AUTHORITY
VADAVATHOOR, KOTTAYAM
Telephone No. 0481 2994540, Email- qcdlkottayam@gmail.com



Test Report

ULR – TC1049526000000399F

Report no :K537/KTM/05/2026	Date : 11.05.2026
-----------------------------	-------------------

Customer Name & Address VIMALAMBIKA SENIOR SECONDARY SCHOOL PAMPADY KOTTAYAM	1.Date of Receipt	06.05.2026
	2.Sampling done by	CUSTOMER
	3.Sample Code	2026/QC/KTM/K1324
	4.Source of Sample	WELL
	5.Sample Quantity	2 Litre
	6 Sample condition	Acceptable
	7.Test performing date	06.05.2026-07.05.2026


Sl. No	Characteristics	Unit	Test Method	Acceptable limits As per IS 10500:2012.	Limit of detection	Result
1	Colour	HU	APHA-24 th Edition (2023) 2120 B – Visual comparison method	5	1	5
2	Odour		IS 3025 (Part 5) 2018	Agreeable	Agreeable	Agreeable
3	Taste		IS 3025 (Part 8) :2023	Agreeable	Agreeable	Agreeable
4	Turbidity	NTU	IS 3025 (Part10):2023 Nephelometric Method	1	0.5	BDL
5	P ^H at 25 °C		IS 3025 (Part 11) – 2022 Potentiometric Method	6.5 - 8.5	2	6.2
6	Total Alkalinity (as CaCO ₃)	mg/l	IS 3025 (Part 23) :2023 Indicator Method	200	5	12.0
7	Total dissolved solids (TDS) at 180° C	mg/l	IS 3025 (Part 16) :2023 Gravimetric Method	500	5	99
8	Total Hardness (as CaCO ₃)	mg/l	IS 3025 (Part21) - 2009 (Reaffirmed 2023) - EDTA Method	200	5	48
9	Calcium (as Ca)	mg/l	IS 3025 (Part 40) :2024 EDTA Titrimetric Method	75	5	8.0
10	Magnesium (as Mg)	mg/l	APHA 24 th Edition (2023) 3500 – Mg B Calculation Method	30	5	6.8

Remarks:

NB: - The result stated above related only to the sample(s) submitted for testing. This test Certificate shall not be reproduced except in full without the written approval of the laboratory

- * Sampling is not done by the Lab
- * BDL - Below Detection Limit
- * NT- Not Tested
- * Samples will be retained only for 7 days after completion of analysis

Verified By
Dhanyamol.K



Authorized Signatory
(Signature with Name)
Rohini K.R

Page 1-2
SANITARY CHEMIST
Quality Control District Lab
Kerala Water Authority
Vadavathoor P.O.
Kottayam - 686010



TC-10495

K

QUALITY CONTROL DISTRICT LAB
KERALA WATER AUTHORITY
VADAVATHOOR, KOTTAYAM
Telephone No. 0481 2994540, Email- gcdlkottayam@gmail.com



Test Report

ULR – TC1049526000000399F

Report no : K537/KTM/05/2026

Date : 11.05.2026

Customer Name & Address VIMALAMBIKA SENIOR SECONDARY SCHOOL PAMPADY KOTTAYAM	1.Date of Receipt	06.05.2026
	2.Sampling done by	CUSTOMER
	3.Sample Code	2026/QC/KTM/K1324
	4.Source of Sample	WELL
	5.Sample Quantity	2 Litre
	6 Sample condition	Acceptable
	7.Test performing date	06.05.2026-07.05.2026


Sl. No	Characteristics	Unit	Test Method	Acceptable limits As per IS 10500:2012	Limit of detection	Result
11	Chloride (as Cl)	mg/l	IS 3025 (Part32):2025 Argentometric Method	250	5	22.9
12	Electrical Conductivity at 25 °C	µS/cm	IS 3025 (Part14) -2013 (Reaffirmed 2023)		10 µS/cm	162
13	Acidity	mg/l	IS 3025 (Part22) :2024 Indicator Method		5	10
14	Sulphate (as SO ₄)	mg/l	IS 3025 (Part24 / Sec1) 2022 Turbidity Method	200	1	23.1
15	Fluoride (as F)	mg/l	APHA 24th Edition 4500 -F D SPADNS Method	1	0.1	BDL
16	Iron (as Fe)	mg/l	IS 3025 (Part 53) : 2024 Phenanthroline Method	1	0.1	0.3
17	Nitrate(as NO ₃)	mg/l	APHA 24th Edition 4500- NO ₃ – B Ultraviolet Spectrophotometric Screening Method	45	1	BDL

Remarks: -NB:- The result stated above related only to the sample(s) submitted for testing. This test Certificate shall not be reproduced except in full without the written approval of the laboratory

- * Sampling is not done by the Lab
- * BDL – Below Detection Limit
- * NT- Not Tested
- * Samples will be retained only for 7 days after completion of analysis

Verified By

Dhanyamed.K



KWA/KTM/AR/F3

Issue No.03

Issue Date: 07.05.2024

Rev. 04

Authorized Signatory
(Signature with Name)

Rohini K.R

SANITARY CHEMIST
Quality Control District Lab
Kerala Water Authority
Vadavathoor P.O.
Kottayam

Page 2-2

Rev Date: 01.01.2026

QUALITY CONTROL DISTRICT LAB

KERALA WATER AUTHORITY

VADAVATHOOR, KOTTAYAM

Telephone No. 0481 2994540, Email - qcdlkottayam@gmail.com



Test Report

Report no : K537/KTM/05/2026

Date : : 11.05.2026

Customer Name & Address VIMALAMBIKA SENIOR SECONDARY SCHOOL PAMPADY KOTTAYAM	1.Date of Receipt	06.05.2026
	2.Sampling done by	CUSTOMER
	3.Sample Code	2026/QC/KTM/K1324
	4.Source of Sample	WELL
	5.Sample Quantity	2 Litre
	6 Sample condition	Acceptable
	7.Test performing date	06.05.2026-07.05.2026

Sl. No	Characteristics	Unit	Test Method	Acceptable limits As per IS 10500:2012	Limit of detection	Result
1	Residual Chlorine	mg/l	Kit Method	0.2	-	NIL
2	Aluminum	mg/l	IS 3025 (Part 55) :2003(Reaffirmed 2023)-Eriochrome Cyanine R Method	0.03	-	NT
3	Dissolved Oxygen	mg/l	IS 3025 (Part 38) :2025 Winkler Method	-	-	NT
4	Chemical Oxygen demand	mg/l	IS 3025(part 58)2006 (Reaffirmed 2023)- open Reflux method	-	-	NT
5	Biological Oxygen Demand	mg/l	IS 3025(part 44):2023- oxygen Depletion method	-	-	NT
6	Total Suspended Solids @103°C-105°C (TSS)	mg/l	IS 3025(part 17)2022Gravimetric Method	-	-	NT
7	Oil & Grease	mg/l	IS 3025 (Part 39) 2021 - Liquid _Liquid Partition Gravimetric method	-	-	NT

Remarks: -NB:- The result stated above related only to the sample(s) submitted for testing. This test Certificate shall not be reproduced except in full without the written approval of the laboratory

- * Sampling is not done by the Lab
- * BDL - Below Detection Limit
- * NT- Not Tested
- * Samples will be retained only for 7 days after completion of analysis


Verified By
Dhanyamol K

KWA/KTM/AR/F3

Issue No.03

Issue Date: 07.05.2024

Rev. 05



Authorized Signatory
(Signature with Name)
Rohini K
SANITARY CHEMIST
Quality Control District Lab
Kerala Water Authority
Vadavathoor P.O.
Kottayam - 686010



QUALITY CONTROL DISTRICT LAB
KERALA WATER AUTHORITY

VADAVATHOOR, KOTTAYAM
Telephone No. 0481 2994540, Email- qcdlkottayam@gmail.com

TEST REPORT



ULR – TC1049526000000399F

Report No: K537/KTM/05/2026

Date: 11.05.2026

Customer Name & Address VIMALAMBIKA SENIOR SECONDARY SCHOOL PAMPADY KOTTAYAM	1.Date of Receipt	06.05.2026
	2.Sampling done by	CUSTOMER
	3.Sample Code	2026/QC/KTM/K1324
	4.Source of Sample	WELL
	5.Sample Quantity	200 ml
	6.Sample Condition	Acceptable
	7.Test performing date	06.05.2026 – 09.05.2026

BACTERIOLOGICAL ANALYSIS

Sl No.	Parameters	Acceptable limits as per – IS 10500-2012	Test Method	Result
1	Coliforms	Shall not be detected/100ml	IS 15185:2016 (Reaffirmed 2021)	ABSENT
2	E-coli	Shall not be detected/100ml	IS 15185:2016 (Reaffirmed 2021)	ABSENT

Test method

Coliforms: Membrane Filtration Method

E. coli: Membrane Filtration Method

Remarks: -

NB:- The result stated above related only to the sample(s) submitted for testing. This test Certificate shall not be reproduced except in full without the written approval of the laboratory

*Samples will be retained only for 7 days after completion of analysis

*Sampling is not done by the Lab



KWA/KTM/AR/F4

Issue No.01

Issue Date: 22.05.2021

Rev. No.04

Rev. Date: 13.04.2026

Authorized By
(Signature with Name)
Page 1-1

MICROBIOLOGIST
Quality Control District Lab
Kerala Water Authority
Vadavathoor P.O.
Kottayam - 686010